CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/NMK/W.No.16/2017-18

Date: 08.03.2018

TEST REPORT ON CONCRETE CUBES

Client : **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
Contractor : **Sri. N.M Krishnamurthy,** Contractor, Bangalore.
Name of the work : Improvements to road, drain and otheer works in Khatha Nagar in Ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in Ward No.16, BBMP, Bangalore.

Sample ID : Cement Concrete
Size of cubes : 150mmx150mmx150mm
Cross Sectional Area : 22500 mm^2
Technical Reference : IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete : M_{10}
Compressive Strength as on : 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	08.02.2018	08.03.2018	8.166	268.2	11.92
2	08.02.2018	08.03.2018	8.180	255.6	11.36
3	08.02.2018	08.03.2018	8.164	286.1	12.72

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/NMK/W.No.16/2017-18

29.01.2018

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	: **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
Agency	: **Sri. N.M. Krishnamurthy,** Contractor, Bangalore.
Name of the work	: Improvements to road, drain and other works in Khatha Nagar in ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in ward No.16, BBMP, Bangalore.
Sample ID	: Cement Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M_{20}
Compressive Strength as on	: 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	22.01.2018	29.01.2018	8.147	326.5	14.51
2	22.01.2018	29.01.2018	8.152	342.8	15.24
3	22.01.2018	29.01.2018	8.163	338.9	15.06

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/NMK/W.No.16/2017-18

19.02.2018

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	: **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
Agency	: **Sri. N.M. Krishnamurthy,** Contractor, Bangalore.
Name of the work	: Improvements to road, drain and other works in Khatha Nagar in ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in ward No.16, BBMP, Bangalore.
Sample ID	: Cement Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M_{20}
Compressive Strength as on	: 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	22.01.2018	19.02.2018	8.259	523.6	23.27
2	22.01.2018	19.02.2018	8.263	499.3	22.19
3	22.01.2018	19.02.2018	8.274	516.2	22.94

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/NMK/W.No.16/2017-18

29.01.2018

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	: **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
Agency	: **Sri. N.M. Krishnamurthy,** Contractor, Bangalore.
Name of the work	: Improvements to road, drain and other works in Khatha Nagar in ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in ward No.16, BBMP, Bangalore.
Sample ID	: Cement Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M_{20}
Compressive Strength as on	: 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	22.01.2018	29.01.2018	8.147	326.5	14.51
2	22.01.2018	29.01.2018	8.163	342.8	15.24
3	22.01.2018	29.01.2018	8.158	338.9	15.06

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/NMK/W.No.16/2017-18

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

19.02.2018

Client	: **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
Agency	: **Sri. N.M. Krishnamurthy,** Contractor, Bangalore.
Name of the work	: Improvements to road, drain and other works in Khatha Nagar in ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in ward No.16, BBMP, Bangalore.
Sample ID	: Cement Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M_{20}
Compressive Strength as on	: 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	22.01.2018	19.02.2018	8.259	536.2	23.83
2	22.01.2018	19.02.2018	8.263	512.4	22.77
3	22.01.2018	19.02.2018	8.286	524.8	23.32

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED

Ref No: CQCE/BBMP/NMK/W.No.16/2017-18

21.02.2018

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	: **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
Agency	: **Sri. N.M. Krishnamurthy,** Contractor, Bangalore.
Name of the work	: Improvements to road, drain and other works in Khatha Nagar in ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in ward No.16, BBMP, Bangalore.
Sample ID	: Cement Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M_{20}
Compressive Strength as on	: 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	14.02.2018	21.02.2018	8.156	320.6	14.25
2	14.02.2018	21.02.2018	8.168	348.3	15.48
3	14.02.2018	21.02.2018	8.152	365.2	16.23

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED

Ref No.: CQCE/BBMP/NMK/W.No.16/2017-18

14.03.2018

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	: **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
Agency	: **Sri. N.M. Krishnamurthy,** Contractor, Bangalore.
Name of the work	: Improvements to road, drain and other works in Khatha Nagar in ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in ward No.16, BBMP, Bangalore.
	: Cement Concrete
Sample ID	: 150mmx150mmx150mm
Size of cubes	: 22500 mm^2
Cross Sectional Area	: IS: 516-1959 (Reaffirmed 2008)
Technical Reference	: M_{20}
Grade of Concrete	: 28th day
Compressive Strength as on	

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	14.02.2018	14.03.2018	8.228	520.2	23.12
2	14.02.2018	14.03.2018	8.282	489.6	21.76
3	14.02.2018	14.03.2018	8.264	510.3	22.68

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬ,ಪತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED

S.No.: CQCE/BBMP/NMK/W.No.16/2017-18

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

21.02.2018

Client	: **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
Agency	: **Sri. N.M. Krishnamurthy,** Contractor, Bangalore.
Name of the work	: Improvements to road, drain and other works in Khatha Nagar in ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in ward No.16, BBMP, Bangalore.
Sample ID	: Cement Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M_{20}
Compressive Strength as on	: 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	14.02.2018	21.02.2018	8.168	339.5	15.09
2	14.02.2018	21.02.2018	8.182	365.2	16.23
3	14.02.2018	21.02.2018	8.155	348.3	15.48

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2008 CERTIFIED

No. CQCE/BBMP/NMK/W.No.16/2017-18

14.03.2018

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

	: **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
	: **Sri. N.M. Krishnamurthy,** Contractor, Bangalore.
ne of the work	: Improvements to road, drain and other works in Khatha Nagar in ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in ward No.16, BBMP, Bangalore.
	: Cement Concrete
ple ID	: 150mmx150mmx150mm
e of cubes	
ss Sectional Area	: 22500 mm^2
hnical Reference	: IS: 516-1959 (Reaffirmed 2008)
de of Concrete	: M_{20}
mpressive Strength as on	: 28th day

S.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	14.02.2018	14.03.2018	8.218	530.2	23.56
2	14.02.2018	14.03.2018	8.280	518.9	23.06
3	14.02.2018	14.03.2018	8.264	539.1	23.96

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಧಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED

No: CQCE/BBMP/NMK/W.No.16/2017-18

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

21.02.2018

	: **Executive Engineer,** RR Nagar Division, BBMP, Bangalore.
	: **Sri. N.M. Krishnamurthy,** Contractor, Bangalore.
of the work	: Improvements to road, drain and other works in Khatha Nagar in ward No.16 and Improvements to road drain and other works in Siddharata Nagar, Peenya Plantation in ward No.16, BBMP, Bangalore.
	: Cement Concrete
ple ID	: 150mmx150mmx150mm
of cubes	
s Sectional Area	: 22500 mm^2
hnical Reference	: IS: 516-1959 (Reaffirmed 2008)
de of Concrete	: M_{20}
mpressive Strength as on	: 7th day

S.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	14.02.2018	21.02.2018	8.165	336.2	14.94
2	14.02.2018	21.02.2018	8.182	349.5	15.53
3	14.02.2018	21.02.2018	8.152	352.6	15.67

Note:
The report shall not be reproduced, except in full, without the written approval of the laboratory.
The results indicated above are based on the tests carried out on the samples received in the laboratory.
Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail:civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned by CamScanner